



Grizzly Ranch Community Services District
Consumer Confidence Report
Water System
2019

Grizzly Ranch Community Services District Presents it's 2019 Consumer Confidence Report

The Consumer Confidence Report is produced annually and will provide information on the quality of the water provided to you, our valuable community members. The report includes detailed information about the raw (untreated) water along with the treated water quality that is provided to you in the Grizzly Ranch Community.

The Grizzly Ranch CSD staff has maintained Regulatory compliance in providing clean quality drinking water to the district. Staff has improved operational maintenance and management practices in ensuring quality treatment and distribution of the potable water system. Both operational and administrative staff continue to train in their positions to provide the best service they can to the district.

The Grizzly Ranch CSD Board of Directors, which consists of 5 community members, continues to provide a dedicated approach to the direction and guidance of CSD operations. The Board has made huge strides in 2019 implementing policies, procedures and working groups to further assist in the CSD needs.

The CSD Board of Directors and Staff will continue to work as a team to keep improving the District's position into the future while maintaining the confidence of its consumers. We encourage you to follow us on the CSD website: www.grizzlyranchcsd.com. The website contains information regarding Board meetings, financials, fees and operations updates.

Thank you,

Grizzly Ranch Community Services District Board and Staff

2019 Consumer Confidence Report

Water System Name: Grizzly Ranch CSD

Report Date: 4/13/20

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2019 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Grizzly Ranch CSD a 4456 Grizzly Rd. Portola, CA. 96122, 530-832-4716 para asistirlo en español.

这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Grizzly Ranch CSD 以获得中文的帮助: 4456 Grizzly Rd. Portola, CA. 96122, 530-832-4716.

Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Grizzly Ranch CSD 4456 Grizzly Rd. Portola, CA. 96122 o tumawag sa 530-832-4716 para matulungan sa wikang Tagalog.

Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Grizzly Ranch CSD tại 4456 Grizzly Rd. Portola, CA. 96122, 530-832-4716 để được hỗ trợ giúp bằng tiếng Việt.

Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Grizzly Ranch CSD ntawm 4456 Grizzly Rd. Portola, CA. 96122, rau kev pab ha 530-832-4716 uv lus Askiv.

Type of water source(s) in use: Wells

Name & general location of source(s): Well 3p2- Fox Sparrow Dr., Well 9M- Fox Sparrow Dr., Well 1P- Yarrow Ln.

Drinking Water Source Assessment information: _____

Time and place of regularly scheduled board meetings for public participation:

Grizzly Ranch CSD Board meetings are regularly scheduled on a FY quarterly basis on the second Tuesday in the months of June, September, December and March. The Board meetings are held at the Grizzly Ranch Outpost located at 300 Clubhouse Dr. and start at 9am. Board meeting schedules, agendas and minutes are available at www.grizzlyranchcsd.com

For more information, contact: Aaron Corr, General Manager, GRCS D

Phone: (530) 832-4716

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variations and Exemptions: Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if

is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter ($\mu\text{g/L}$)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (state Total Coliform Rule)	(In a month)	0	1 positive monthly sample ^(a)	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (state Total Coliform Rule)	(In the year)	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive	0	Human and animal fecal waste
<i>E. coli</i> (federal Revised Total Coliform Rule)	(In the year)	0	(b)	0	Human and animal fecal waste

(a) Two or more positive monthly samples is a violation of the MCL
 (b) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER								
Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	7/9/17 to 7/12/17	5	0	0	15	0.2	Not applicable	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	7/9/17 to 7/12/17	5	0.118	0	1.3	0.3	Not applicable	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	4/18/17	44		None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	4/18/17	832		None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
See attachments for breakdowns						

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
See attachments for breakdowns						

TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
See attachments for breakdowns					

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Grizzly Ranch CSD is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [**OPTIONAL:** If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

**Summary Information for Violation of a MCL, MRDL, AL, TT,
or Monitoring and Reporting Requirement**

VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
N/A	N/A	N/A	N/A	N/A

For Water Systems Providing Groundwater as a Source of Drinking Water

TABLE 7 – SAMPLING RESULTS SHOWING FECAL INDICATOR-POSITIVE GROUNDWATER SOURCE SAMPLES					
Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	(In the year)	0	0	(0)	Human and animal fecal waste
Enterococci	(In the year)	0	TT	N/A	Human and animal fecal waste
Coliphage	(In the year)	0	TT	N/A	Human and animal fecal waste

**Summary Information for Fecal Indicator-Positive Groundwater Source Samples,
Uncorrected Significant Deficiencies, or Groundwater TT**

SPECIAL NOTICE OF FECAL INDICATOR-POSITIVE GROUNDWATER SOURCE SAMPLE				
N/A				
SPECIAL NOTICE FOR UNCORRECTED SIGNIFICANT DEFICIENCIES				
N/A				
VIOLATION OF GROUNDWATER TT				
TT Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
N/A	N/A	N/A	N/A	N/A

--	--	--	--	--

For Systems Providing Surface Water as a Source of Drinking Water

TABLE 8 - SAMPLING RESULTS SHOWING TREATMENT OF SURFACE WATER SOURCES

Treatment Technique ^(a) (Type of approved filtration technology used)	
Turbidity Performance Standards ^(b) (that must be met through the water treatment process)	Turbidity of the filtered water must: 1 – Be less than or equal to ____ NTU in 95% of measurements in a month. 2 – Not exceed ____ NTU for more than eight consecutive hours. 3 – Not exceed ____ NTU at any time.
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	
Highest single turbidity measurement during the year	
Number of violations of any surface water treatment requirements	

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

Summary Information for Violation of a Surface Water TT

VIOLATION OF A SURFACE WATER TT

TT Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
N/A	N/A	N/A	N/A	N/A

Summary Information for Operating Under a Variance or Exemption

N/A

**Summary Information for Federal Revised Total Coliform Rule
Level 1 and Level 2 Assessment Requirements**

Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

During the past year we were required to conduct 0 Level 1 assessment(s). 0 Level 1 assessment(s) were completed. In addition, we were required to take [INSERT NUMBER OF CORRECTIVE ACTIONS] corrective actions and we completed [INSERT NUMBER OF CORRECTIVE ACTIONS] of these actions.

During the past year 0 Level 2 assessments were required to be completed for our water system. 0 Level 2 assessments were completed. In addition, we were required to take 0 corrective actions and we completed 0 of these actions.

N/A

Level 2 Assessment Requirement Due to an *E. coli* MCL Violation

E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely-compromised immune systems. We found *E. coli* bacteria, indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) identify problems and to correct any problems that were found during these assessments.

We were required to complete a Level 2 assessment because we found *E. coli* in our water system. In addition, we were required to take 0 corrective actions and we completed 0 of these actions.

N/A

Attachment #1

**Grizzly Ranch CSD Lead and Copper Monitoring
History**

Individual System Lead and Copper Rule Tracking Report

3205006 Grizzly Ranch CSD Pop: 0 Eng: Lead Action Level: 0.015 mg/L
 Copper Action Level: 1.3 mg/L

Sample Date Begin/(End)	Monitoring Period	Sample Set ID	Number Required	Number Sampled	Lead 90th % (mg/L)	Copper 90th % (mg/L)	Action Taken	Action Type	Next Due Date	Next Due Freq	Comments
(9/25/2007)	YR2007		5	5	0.019	0.129			8/1/2008		Lead Exceedance
(7/22/2008)	YR2008		5	5	0.012	0.213			3/1/2009		No Exceedance
(9/10/2009)	YR2009		5	5	0.023	0.182			8/1/2010		Lead Exceedance - 5 samples due
(7/20/2010)	YR2010		5	5	0.026	0.314			3/1/2011		Lead Exceedance - 5 samples due
(9/9/2011)	YR2011		5	5	0.017	0.127			8/1/2012		Lead Exceedance - 5 samples due
(9/24/2013)	YR2013		5	5	0.014	0.431			8/1/2015		No Exceedance
9/16/2014 (10/24/2014)	YR2014		5	5	0.007	0.555			8/1/2017		No Exceedance
7/9/2017 (7/12/2017)	YR2017		5	5	0.000	0.118			8/1/2020		No Exceedance

Legend:
 Cit: Citation
 EL: Enforcement letter

1st 6: 1st initial 6-mo. round of monitoring
 2nd 6: 2nd initial 6-mo. round of monitoring

A1: 1st Annual monitoring
 A2: 2nd Annual monitoring

T1: 1st Triennial (3 yr) monitoring
 T2: 2nd Triennial (3 yr) monitoring
 T3: 3rd Triennial (3 yr) monitoring

Attachment #2

GRCSD

Well 9M

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 LAST SAMPLE FOR ALL CHAPTER 15 CONSTITUENTS - ALL RESULTS
 REPORT OF SYSTEM: 3205006

SYSTEM NO: 3205006 NAME: GRIZZLY RANCH CSD

COUNTY: PLUMAS

SOURCE NO: 003 NAME: WELL 9M

CLASS: CTGP

STATUS: A

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT	*	MCL	DLR	TRIGGER	UNIT		
3205006003	3205006 GRIZZLY RANCH CSD	003	WELL 9M							
DB P	DISINFECTION BYPRODUCTS									
	32101	BROMODICHLOROMETHANE (THM)	2013/07/02	<	.5000	*	-----	1	-----	UG/L
	32104	BROMOFORM (THM)	2013/07/02	<	1.0000	*	-----	1	-----	UG/L
	32106	CHLOROFORM (THM)	2013/07/02	<	.5000	*	-----	1	-----	UG/L
	32105	DIBROMOCHLOROMETHANE (THM)	2013/07/02	<	.5000	*	-----	1	-----	UG/L
	82080	TOTAL TRIHALOMETHANES	2013/07/02	<	1.0000		80	-----	80.000	UG/L
GP	SECONDARY/GP									
	82383	AGGRSSIVE INDEX (CORROSIVITY)	2016/08/16		11.2	*	-----	-----	-----	
	00440	BICARBONATE ALKALINITY	2016/08/16		190	*	-----	-----	-----	MG/L
	00916	CALCIUM	2016/08/16		62	*	-----	-----	-----	MG/L
	00445	CARBONATE ALKALINITY	2016/08/16	<	10	*	-----	-----	-----	MG/L
	00940	CHLORIDE	2016/08/16		3		500	-----	250.000	MG/L
	00081	COLOR	2016/08/16	<	5		15	-----	15.000	UNITS
	01042	COPPER	2016/08/16	<	10		1000	50	1000.000	UG/L
	38260	FOAMING AGENTS (MBAS)	2016/08/16	<	0.1		.5	-----	0.500	MG/L
	00900	HARDNESS (TOTAL) AS CaCO3	2016/08/16		208	*	-----	-----	-----	MG/L
	71830	HYDROXIDE ALKALINITY	2016/08/16	<	10	*	-----	-----	-----	MG/L
	01045	IRON	2020/01/07		9570	*	300	100	300.000	UG/L
	00927	MAGNESIUM	2016/08/16		13	*	-----	-----	-----	MG/L
	01055	MANGANESE	2020/01/07		67.9	*	50	20	50.000	UG/L
	00086	ODOR THRESHOLD @ 60 C	2016/08/16	<	1		3	1	3.000	TON
	00403	PH, LABORATORY	2016/08/16		6.8	*	-----	-----	-----	
	01077	SILVER	2016/08/16	<	1		100	10	100.000	UG/L
	00929	SODIUM	2016/08/16		13	*	-----	-----	-----	MG/L
	00095	SPECIFIC CONDUCTANCE	2016/08/16		487		1600	-----	900.000	US
	00945	SULFATE	2016/08/16		84.6		500	.5	250.000	MG/L
	70300	TOTAL DISSOLVED SOLIDS	2016/08/16		320		1000	-----	500.000	MG/L
	82079	TURBIDITY, LABORATORY	2016/08/16		10.1	*	5	.1	5.000	NTU
	01092	ZINC	2016/08/16		2700		5000	50	5000.000	UG/L

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 LAST SAMPLE FOR ALL CHAPTER 15 CONSTITUENTS - ALL RESULTS
 REPORT OF SYSTEM: 3205006

SYSTEM NO: 3205006 NAME: GRIZZLY RANCH CSD COUNTY: PLUMAS
 SOURCE NO: 003 NAME: WELL 9M CLASS: CTGP STATUS: A

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
3205006003	IO INORGANIC						
	01105	ALUMINUM	2016/08/16 <	10	1000	50	200.000 UG/L
	01097	ANTIMONY	2016/08/16 <	1	6	6	6.000 UG/L
	01002	ARSENIC	2020/01/07 <	2	10	2	5.000 UG/L
	01007	BARIUM	2016/08/16 <	0.2	1000	100	1000.000 UG/L
	01012	BERYLLIUM	2016/08/16 <	1	4	1	4.000 UG/L
	01027	CADMIUM	2016/08/16 <	0.2	5	1	5.000 UG/L
	01034	CHROMIUM (TOTAL)	2016/08/16 <	1	50	10	50.000 UG/L
	01032	CHROMIUM, HEXAVALENT	2017/04/18 <	1	10	1	10.000 UG/L
	01291	CYANIDE	2005/11/04 <	5.0000	150	100	150.000 UG/L
	00951	FLUORIDE (F) (NATURAL-SOURCE)	2016/08/16 <	0.1	2	.1	2.000 MG/L
	01051	LEAD	2016/08/16 <	0.5	-----	5	15.000 UG/L
	71900	MERCURY	2016/08/16 <	0.02	2	1	2.000 UG/L
	01067	NICKEL	2016/08/16 <	1	100	10	100.000 UG/L
	A-031	PERCHLORATE	2019/04/09 <	4	6	4	4.000 UG/L
	01147	SELENIUM	2016/08/16 <	1	50	5	50.000 UG/L
	01059	THALLIUM	2016/08/16 <	0.2	2	1	2.000 UG/L
NI	NITRATE/NITRITE						
	00618	NITRATE (AS N)	2019/04/09 <	0.4	10	.4	5.000 mg/L
	71850	NITRATE (AS NO3)	2013/07/02 <	.4000	45	2	23.000 MG/L
	A-029	NITRATE + NITRITE (AS N)	2016/08/16 <	0.1	10	.4	5.000 mg/L
	00620	NITRITE (AS N)	2019/04/09 <	0.4	1	.4	0.500 mg/L
RA	RADIOLOGICAL						
	01501	GROSS ALPHA	2016/08/16	0.712	15	3	5.000 PCI/L
	01502	GROSS ALPHA COUNTING ERROR	2016/08/16	1.18 *	-----	-----	----- PCI/L
	A-072	GROSS ALPHA MDA95	2016/08/16	1.47 *	-----	-----	----- PCI/L
	03501	GROSS BETA	2005/11/04	1.7400	50	4	50.000 PCI/L
	03502	GROSS BETA COUNTING ERROR	2005/11/04	.9570 *	-----	-----	----- PCI/L
	11501	RADIUM 228	2017/02/14	1 *	-----	1	----- PCI/L
	11502	RADIUM 228 COUNTING ERROR	2017/02/14	0.400 *	-----	-----	----- PCI/L
	A-075	RADIUM 228 MDA95	2017/02/14	0.192 *	-----	-----	----- PCI/L
	28012	URANIUM (PCI/L)	2005/11/04	1.7400	20	2	20.000 PCI/L

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 LAST SAMPLE FOR ALL CHAPTER 15 CONSTITUENTS - ALL RESULTS
 REPORT OF SYSTEM: 3205006

SYSTEM NO: 3205006 NAME: GRIZZLY RANCH CSD COUNTY: PLUMAS
 SOURCE NO: 003 NAME: WELL 9M CLASS: CTGP STATUS: A

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
3205006003	RA RADIOLOGICAL						
	28012 URANIUM (PCI/L)	2005/11/04 <	1.0000	20	2	20.000	PCI/L
	A-028 URANIUM COUNTING ERROR	2005/11/04	.9570 *	-----	-----	-----	PCI/L
	S1 REGULATED VOC						
	34506 1,1,1-TRICHLOROETHANE	2019/04/09 <	0.5	200	.5	0.500	UG/L
	34516 1,1,2,2-TETRACHLOROETHANE	2019/04/09 <	0.5	1	.5	0.500	UG/L
	34511 1,1,2-TRICHLOROETHANE	2019/04/09 <	0.5	5	.5	0.500	UG/L
	34496 1,1-DICHLOROETHANE	2019/04/09 <	0.5	5	.5	0.500	UG/L
	34501 1,1-DICHLOROETHYLENE	2019/04/09 <	0.5	6	.5	0.500	UG/L
	34551 1,2,4-TRICHLOROBENZENE	2019/04/09 <	0.5	5	.5	0.500	UG/L
	34536 1,2-DICHLOROBENZENE	2019/04/09 <	0.5	600	.5	0.500	UG/L
	34531 1,2-DICHLOROETHANE	2019/04/09 <	0.5	.5	.5	0.500	UG/L
	34541 1,2-DICHLOROPROPANE	2019/04/09 <	0.5	5	.5	0.500	UG/L
	34561 1,3-DICHLOROPROPENE (TOTAL)	2019/04/09 <	0.5	.5	.5	0.500	UG/L
	34571 1,4-DICHLOROBENZENE	2019/04/09 <	0.5	5	.5	0.500	UG/L
	34030 BENZENE	2019/04/09 <	0.5	1	.5	0.500	UG/L
	32102 CARBON TETRACHLORIDE	2019/04/09 <	0.5	.5	.5	0.500	UG/L
	77093 CIS-1,2-DICHLOROETHYLENE	2019/04/09 <	0.5	6	.5	0.500	UG/L
	34423 DICHLOROMETHANE	2019/04/09 <	0.5	5	.5	0.500	UG/L
	34371 ETHYL BENZENE	2019/04/09 <	0.5	300	.5	0.500	UG/L
	46491 METHYL-TERT-BUTYL-ETHER (MTBE)	2019/04/09 <	3.0	13	3	3.000	UG/L
	34301 MONOCHLOROBENZENE	2019/04/09 <	0.5	70	.5	0.500	UG/L
	77128 STYRENE	2019/04/09 <	0.5	100	.5	0.500	UG/L
	34475 TETRACHLOROETHYLENE	2019/04/09 <	0.5	5	.5	0.500	UG/L
	34010 TOLUENE	2019/04/09 <	0.5	150	.5	0.500	UG/L
	34546 TRANS-1,2-DICHLOROETHYLENE	2019/04/09 <	0.5	10	.5	0.500	UG/L
	39180 TRICHLOROETHYLENE	2019/04/09 <	0.5	5	.5	0.500	UG/L
	34488 TRICHLOROFLUOROMETHANE FREON 11	2019/04/09 <	5	150	5	5.000	UG/L
	81611 TRICHLOROTRIFLUOROETHANE (FREON 113)	2019/04/09 <	10	1200	10	10.000	UG/L

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 LAST SAMPLE FOR ALL CHAPTER 15 CONSTITUENTS - ALL RESULTS
 REPORT OF SYSTEM: 3205006

SYSTEM NO: 3205006 NAME: GRIZZLY RANCH CSD COUNTY: PLUMAS
 SOURCE NO: 003 NAME: WELL 9M CLASS: CTGP STATUS: A

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
3205006003	S1 REGULATED VOC						
	39175 VINYL CHLORIDE	2019/04/09 <	0.5	.5	.5	0.500	UG/L
	81551 XYLENES (TOTAL)	2019/04/09 <	0.5	1750	0.5	1750.000	UG/L
S2	REGULATED SOC						
	7744X 1,2,3-TRICHLOROPROPANE (1,2,3-TCP)	2005/11/04 <	.0000	-----	0.005	0.005	UG/L
	77443 1,2,3-TRICHLOROPROPANE (1,2,3-TCP)	2018/04/10 <	0.005	0.005	0.005	0.005	UG/L
	38761 DIBROMOCHLOROPROPANE (DBCP)	2005/11/04 <	.0000	.2	.01	0.010	UG/L
UA	STATE UCMR						
	77562 1,1,1,2-TETRACHLOROETHANE	2019/04/09 <	0.5	-----	.5	0.500	UG/L
	01020 BORON	2016/08/16 <	0.1	-----	100	1000.000	UG/L
	34668 DICHLORODIFLUOROMETHANE (FREON 12)	2019/04/09 <	0.5	-----	0.5	1000.000	UG/L
	A-033 ETHYL-TERT-BUTYL ETHER	2019/04/09 <	3 *	-----	3	-----	UG/L
	A-034 TERT-AMYL-METHYL ETHER (TAME)	2019/04/09 <	3 *	-----	3	-----	UG/L
	01087 VANADIUM	2016/08/16 <	2	-----	3	50.000	UG/L
UB	UNREG. TABLE B						
	77222 1,2,4-TRIMETHYLBENZENE	2019/04/09 <	0.5	-----	0.5	330.000	UG/L
	A-011 P-ISOPROPYLTOLUENE	2019/04/09 <	0.5 *	-----	-----	-----	UG/L
XX	GENERAL NON CHAP 15						
	A-007 1,1-DICHLOROPROPANE	2005/11/04 <	.0000	-----	-----	-----	UG/L
	77168 1,1-DICHLOROPROPENE	2019/04/09 <	0.5	-----	.5	0.500	UG/L
	77613 1,2,3-TRICHLOROBENZENE	2019/04/09 <	0.5	-----	.5	0.500	UG/L
	77226 1,3,5-TRIMETHYLBENZENE	2019/04/09 <	0.5	-----	0.5	330.000	UG/L
	34566 1,3-DICHLOROBENZENE	2019/04/09 <	0.5	-----	.5	600.000	UG/L
	77173 1,3-DICHLOROPROPANE	2019/04/09 <	0.5	-----	.5	0.500	UG/L
	77170 2,2-DICHLOROPROPANE	2019/04/09 <	0.5	-----	.5	0.500	UG/L
	A-008 2-CHLOROTOLUENE	2019/04/09 <	0.5	-----	0.5	0.500	UG/L
	A-009 4-CHLOROTOLUENE	2019/04/09 <	0.5	-----	0.5	0.500	UG/L
	00410 ALKALINITY (TOTAL) AS CaCO3	2016/08/16	150 *	-----	-----	-----	MG/L
	81555 BROMOBENZENE	2019/04/09 <	0.5	-----	.5	0.500	UG/L
	A-012 BROMOCHLOROMETHANE	2019/04/09 <	0.5	-----	.5	0.500	UG/L
	34413 BROMOMETHANE	2019/04/09 <	0.5	-----	.5	0.500	UG/L

Attachment #3

GRCSD Well 3P2

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 LAST SAMPLE FOR ALL CHAPTER 15 CONSTITUENTS - ALL RESULTS
 REPORT OF SYSTEM: 3205006

SYSTEM NO: 3205006 NAME: GRIZZLY RANCH CSD

COUNTY: PLUMAS

SOURCE NO: 002 NAME: WELL 3P2

CLASS: CTGP

STATUS: A

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
3205006002	3205006 GRIZZLY RANCH CSD	002	WELL 3P2				
DB P	DISINFECTION BYPRODUCTS						
	32101	BROMODICHLOROMETHANE (THM)	2014/11/11 <	.5000 *	-----	1	----- UG/L
	32104	BROMOFORM (THM)	2014/11/11 <	.5000 *	-----	1	----- UG/L
	32106	CHLOROFORM (THM)	2014/11/11 <	.5000 *	-----	1	----- UG/L
	32105	DIBROMOCHLOROMETHANE (THM)	2014/11/11 <	.5000 *	-----	1	----- UG/L
	82080	TOTAL TRIHALOMETHANES	2014/11/11 <	.5000	80	-----	80.000 UG/L
GP	SECONDARY/GP						
	82383	AGGRSSIVE INDEX (CORROSIVITY)	2011/07/26	11.1000 *	-----	-----	-----
	00440	BICARBONATE ALKALINITY	2011/07/26	160.0000 *	-----	-----	----- MG/L
	00916	CALCIUM	2011/07/26	45.0000 *	-----	-----	----- MG/L
	00445	CARBONATE ALKALINITY	2011/07/26 <	10.0000 *	-----	-----	----- MG/L
	00940	CHLORIDE	2014/07/08	1.0000	500	-----	250.000 MG/L
	00081	COLOR	2014/07/08	5.0000	15	-----	15.000 UNITS
	01042	COPPER	2014/07/08	23.0000	1000	50	1000.000 UG/L
	38260	FOAMING AGENTS (MBAS)	2014/07/08 <	.1000	.5	-----	0.500 MG/L
	00900	HARDNESS (TOTAL) AS CaCO3	2011/07/26	170.0000 *	-----	-----	----- MG/L
	71830	HYDROXIDE ALKALINITY	2011/07/26 <	10.0000 *	-----	-----	----- MG/L
	01045	IRON	2020/01/07	3850 *	300	100	300.000 UG/L
	00927	MAGNESIUM	2011/07/26	14.0000 *	-----	-----	----- MG/L
	01055	MANGANESE	2020/01/07	364 *	50	20	50.000 UG/L
	00086	ODOR THRESHOLD @ 60 C	2014/07/08	32.0000 *	3	1	3.000 TON
	00403	PH, LABORATORY	2011/07/26	6.9000 *	-----	-----	-----
	01077	SILVER	2014/07/08 <	1.0000	100	10	100.000 UG/L
	00929	SODIUM	2011/07/26	13.0000 *	-----	-----	----- MG/L
	00095	SPECIFIC CONDUCTANCE	2014/07/08	358.0000	1600	-----	900.000 US
	00945	SULFATE	2014/07/08	56.7000	500	.5	250.000 MG/L
	70300	TOTAL DISSOLVED SOLIDS	2011/07/26	250.0000	1000	-----	500.000 MG/L
	82079	TURBIDITY, LABORATORY	2014/07/08	52.7000 *	5	.1	5.000 NTU
	01092	ZINC	2014/07/08	400.0000	5000	50	5000.000 UG/L

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 LAST SAMPLE FOR ALL CHAPTER 15 CONSTITUENTS - ALL RESULTS
 REPORT OF SYSTEM: 3205006

SYSTEM NO: 3205006 NAME: GRIZZLY RANCH CSD

COUNTY: PLUMAS

SOURCE NO: 002 NAME: WELL 3P2

CLASS: CTGP

STATUS: A

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
3205006002	IO INORGANIC						
	01105 ALUMINUM	2014/07/08	50.0000	1000	50	200.000	UG/L
	01097 ANTIMONY	2014/07/08 <	1.0000	6	6	6.000	UG/L
	01002 ARSENIC	2020/01/07 <	2	10	2	5.000	UG/L
	01007 BARIUM	2014/07/08	63.2000	1000	100	1000.000	UG/L
	01012 BERYLLIUM	2014/07/08 <	.2000	4	1	4.000	UG/L
	01027 CADMIUM	2014/07/08 <	.2000	5	1	5.000	UG/L
	01034 CHROMIUM (TOTAL)	2014/07/08	5.0000	50	10	50.000	UG/L
	01032 CHROMIUM, HEXAVALENT	2017/04/18 <	1	10	1	10.000	UG/L
	00951 FLUORIDE (F) (NATURAL-SOURCE)	2014/07/08 <	.1000	2	.1	2.000	MG/L
	01051 LEAD	2014/07/08	6.5000	-----	5	15.000	UG/L
	71900 MERCURY	2014/07/08	.0600	2	1	2.000	UG/L
	01067 NICKEL	2014/07/08	3.0000	100	10	100.000	UG/L
	A-031 PERCHLORATE	2019/04/09 <	4	6	4	4.000	UG/L
	00660 PHOSPHATE, ORTHO	2005/06/14 <	.0200 *	-----	-----	-----	MG/L
	01147 SELENIUM	2014/07/08 <	1.0000	50	5	50.000	UG/L
	01059 THALLIUM	2014/07/08 <	.2000	2	1	2.000	UG/L
	NI NITRATE/NITRITE						
	00618 NITRATE (AS N)	2019/04/09 <	0.4	10	.4	5.000	mg/L
	71850 NITRATE (AS NO3)	2014/07/08 <	.4000	45	2	23.000	MG/L
	A-029 NITRATE + NITRITE (AS N)	2011/07/26 <	.1000	10000	400	5000.000	UG/L
	00620 NITRITE (AS N)	2017/04/18 <	0.4	1	.4	0.500	mg/L
	RA RADIOLOGICAL						
	01501 GROSS ALPHA	2016/01/12	0.637	15	3	5.000	PCI/L
	01502 GROSS ALPHA COUNTING ERROR	2016/01/12	1.12 *	-----	-----	-----	PCI/L
	A-072 GROSS ALPHA MDA95	2016/01/12	1.49 *	-----	-----	-----	PCI/L
	11501 RADIUM 228	2017/02/14	1 *	-----	1	-----	PCI/L
	11502 RADIUM 228 COUNTING ERROR	2017/02/14	0.412 *	-----	-----	-----	PCI/L
	A-075 RADIUM 228 MDA95	2017/02/14	0.200 *	-----	-----	-----	PCI/L
	S1 REGULATED VOC						
	34506 1,1,1-TRICHLOROETHANE	2014/11/11 <	.5000	200	.5	0.500	UG/L

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 LAST SAMPLE FOR ALL CHAPTER 15 CONSTITUENTS - ALL RESULTS
 REPORT OF SYSTEM: 3205006

SYSTEM NO: 3205006 NAME: GRIZZLY RANCH CSD COUNTY: PLUMAS
 SOURCE NO: 002 NAME: WELL 3P2 CLASS: CTGP STATUS: A

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
3205006002	S1 REGULATED VOC						
	34516	1,1,2,2-TETRACHLOROETHANE	2014/11/11 <	.5000	1	.5	0.500 UG/L
	34511	1,1,2-TRICHLOROETHANE	2014/11/11 <	.5000	5	.5	0.500 UG/L
	34496	1,1-DICHLOROETHANE	2014/11/11 <	.5000	5	.5	0.500 UG/L
	34501	1,1-DICHLOROETHYLENE	2014/11/11 <	.5000	6	.5	0.500 UG/L
	34551	1,2,4-TRICHLOROBENZENE	2014/11/11 <	.5000	5	.5	0.500 UG/L
	34536	1,2-DICHLOROBENZENE	2014/11/11 <	.5000	600	.5	0.500 UG/L
	34531	1,2-DICHLOROETHANE	2014/11/11 <	.5000	.5	.5	0.500 UG/L
	34541	1,2-DICHLOROPROPANE	2014/11/11 <	.5000	5	.5	0.500 UG/L
	34561	1,3-DICHLOROPROPENE (TOTAL)	2014/11/11 <	.5000	.5	.5	0.500 UG/L
	34571	1,4-DICHLOROBENZENE	2014/11/11 <	.5000	5	.5	0.500 UG/L
	34030	BENZENE	2014/11/11 <	.5000	1	.5	0.500 UG/L
	32102	CARBON TETRACHLORIDE	2014/11/11 <	.5000	.5	.5	0.500 UG/L
	77093	CIS-1,2-DICHLOROETHYLENE	2014/11/11 <	.5000	6	.5	0.500 UG/L
	34423	DICHLOROMETHANE	2014/11/11 <	.5000	5	.5	0.500 UG/L
	34371	ETHYL BENZENE	2014/11/11 <	.5000	300	.5	0.500 UG/L
	46491	METHYL-TERT-BUTYL-ETHER (MTBE)	2014/11/11 <	1.0000	13	3	3.000 UG/L
	34301	MONOCHLOROBENZENE	2014/11/11 <	.5000	70	.5	0.500 UG/L
	77128	STYRENE	2014/11/11 <	.5000	100	.5	0.500 UG/L
	34475	TETRACHLOROETHYLENE	2014/11/11 <	.5000	5	.5	0.500 UG/L
	34010	TOLUENE	2014/11/11 <	.5000	150	.5	0.500 UG/L
	34546	TRANS-1,2-DICHLOROETHYLENE	2014/11/11 <	.5000	10	.5	0.500 UG/L
	39180	TRICHLOROETHYLENE	2014/11/11 <	.5000	5	.5	0.500 UG/L
	34488	TRICHLOROFLUOROMETHANE FREON 11	2014/11/11 <	.5000	150	5	5.000 UG/L
	81611	TRICHLOROTRIFLUOROETHANE (FREON 113)	2014/11/11 <	.5000	1200	10	10.000 UG/L
	39175	VINYL CHLORIDE	2014/11/11 <	.5000	.5	.5	0.500 UG/L
81551	XYLENES (TOTAL)	2014/11/11 <	.5000	1750	0.5	1750.000 UG/L	
	S2 REGULATED SOC						
	7744X	1,2,3-TRICHLOROPROPANE (1,2,3-TCP)	2008/10/14 <	.5000 *	-----	0.005	0.005 UG/L
	77443	1,2,3-TRICHLOROPROPANE (1,2,3-TCP)	2018/04/10 <	0.005	0.005	0.005	0.005 UG/L

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 LAST SAMPLE FOR ALL CHAPTER 15 CONSTITUENTS - ALL RESULTS
 REPORT OF SYSTEM: 3205006

SYSTEM NO: 3205006 NAME: GRIZZLY RANCH CSD

COUNTY: PLUMAS

SOURCE NO: 002

NAME: WELL 3P2

CLASS: CTGP

STATUS: A

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
3205006002	S2 REGULATED SOC						
	38761 DIBROMOCHLOROPROPANE (DBCP)	2005/09/21 <	.0000	.2	.01	0.010	UG/L
	UA STATE UCMR						
	77562 1,1,1,2-TETRACHLOROETHANE	2014/11/11 <	.5000	-----	.5	0.500	UG/L
	01020 BORON	2011/07/26 <	.1000	-----	100	1000.000	UG/L
	34668 DICHLORODIFLUOROMETHANE (FREON 12)	2014/11/11 <	.5000	-----	0.5	1000.000	UG/L
	A-033 ETHYL-TERT-BUTYL ETHER	2014/11/11 <	3.0000 *	-----	3	-----	UG/L
	A-034 TERT-AMYL-METHYL ETHER (TAME)	2014/11/11 <	3.0000 *	-----	3	-----	UG/L
	01087 VANADIUM	2014/07/08 <	2.0000	-----	3	50.000	UG/L
	UB UNREG. TABLE B						
	77222 1,2,4-TRIMETHYLBENZENE	2014/11/11 <	.5000	-----	0.5	330.000	UG/L
	A-011 P-ISOPROPYLTOLUENE	2014/11/11 <	.5000 *	-----	-----	-----	UG/L
	XX GENERAL NON CHAP 15						
	A-007 1,1-DICHLOROPROPANE	2005/09/21 <	.0000	-----	-----	-----	UG/L
	77168 1,1-DICHLOROPROPENE	2014/11/11 <	.5000	-----	.5	0.500	UG/L
	77613 1,2,3-TRICHLOROBENZENE	2014/11/11 <	.5000	-----	.5	0.500	UG/L
	77226 1,3,5-TRIMETHYLBENZENE	2014/11/11 <	.5000	-----	0.5	330.000	UG/L
	34566 1,3-DICHLOROBENZENE	2014/11/11 <	.5000	-----	.5	600.000	UG/L
	77173 1,3-DICHLOROPROPANE	2014/11/11 <	.5000	-----	.5	0.500	UG/L
	77170 2,2-DICHLOROPROPANE	2014/11/11 <	.5000	-----	.5	0.500	UG/L
	A-008 2-CHLOROTOLUENE	2014/11/11 <	.5000	-----	0.5	0.500	UG/L
	A-009 4-CHLOROTOLUENE	2014/11/11 <	.5000	-----	0.5	0.500	UG/L
	00410 ALKALINITY (TOTAL) AS CaCO3	2011/07/26	130.0000 *	-----	-----	-----	MG/L
	81555 BROMOBENZENE	2014/11/11 <	.5000	-----	.5	0.500	UG/L
	A-012 BROMOCHLOROMETHANE	2014/11/11 <	.5000	-----	.5	0.500	UG/L
	34413 BROMOMETHANE	2014/11/11 <	.5000	-----	.5	0.500	UG/L
	77041 CARBON DISULFIDE	2005/09/21 <	.0000	-----	0.5	160.000	UG/L
	34311 CHLOROETHANE	2014/11/11 <	.5000	-----	.5	0.500	UG/L
	34418 CHLOROMETHANE	2014/11/11 <	.5000	-----	.5	0.500	UG/L
	34704 CIS-1,3-DICHLOROPROPENE	2014/11/11 <	.5000	.5	.5	0.500	UG/L

STATE OF CALIFORNIA
DRINKING WATER ANALYSES RESULTS REPORT
LAST SAMPLE FOR ALL CHAPTER 15 CONSTITUENTS - ALL RESULTS
REPORT OF SYSTEM: 3205006

SYSTEM NO:

NAME:

COUNTY:

SOURCE NO:

NAME:

CLASS:

STATUS:

PSCODE		GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
3205006002	XX	77596 DIBROMOMETHANE	2014/11/11 <	.5000	-----	.5	0.500	UG/L
		A-036 DIISOPROPYL ETHER	2014/11/11 <	3.0000 *	-----	3	-----	UG/L
		34391 HEXACHLOROBUTADIENE	2014/11/11 <	.5000	-----	.5	0.500	UG/L
		77223 ISOPROPYLBENZENE	2014/11/11 <	.5000	-----	0.5	770.000	UG/L
		71814 LANGELIER INDEX AT SOURCE TEMP.	2011/07/26 -	.8000 *	-----	-----	-----	
		A-014 M,P-XYLENE	2014/11/11 <	.5000 *	-----	.5	-----	UG/L
		34696 NAPHTHALENE	2014/11/11 <	.5000	-----	0.5	17.000	UG/L
		A-010 N-BUTYLBENZENE	2014/11/11 <	.5000	-----	0.5	0.500	UG/L
		34447 NITROBENZENE	2005/09/21 <	.0000	-----	-----	-----	UG/L
		77224 N-PROPYLBENZENE	2014/11/11 <	.5000	-----	0.5	260.000	UG/L
		77135 O-XYLENE	2014/11/11 <	.5000 *	-----	.5	-----	UG/L
		00937 POTASSIUM	2011/07/26	1.0000 *	-----	-----	-----	MG/L
		77350 SEC-BUTYLBENZENE	2014/11/11 <	.5000	-----	0.5	0.500	UG/L
		00955 SILICA	2005/06/14	30.0000 *	-----	-----	-----	MG/L
		00931 SODIUM ABSORPTION RATIO	2011/07/26	.4000 *	-----	-----	-----	
		77035 TERT-BUTYL ALCOHOL (TBA)	2008/10/14 <	2.0000	-----	2	12.000	UG/L
		77353 TERT-BUTYLBENZENE	2014/11/11 <	.5000	-----	0.5	0.500	UG/L
		34699 TRANS-1,3-DICHLOROPROPENE	2014/11/11 <	.5000 *	.5	.5	-----	UG/L

Attachment #4

GRCSD Well 1P

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 LAST SAMPLE FOR ALL CHAPTER 15 CONSTITUENTS - ALL RESULTS
 REPORT OF SYSTEM: 3205006

SYSTEM NO: 3205006 NAME: GRIZZLY RANCH CSD COUNTY: PLUMAS
 SOURCE NO: 001 NAME: WELL 1P CLASS: CTGP STATUS: A

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
3205006001	3205006 GRIZZLY RANCH CSD	001	WELL 1P				
DB P	DISINFECTION BYPRODUCTS						
	32101	BROMODICHLOROMETHANE (THM)	2014/11/11 <	.5000 *	-----	1	----- UG/L
	32104	BROMOFORM (THM)	2014/11/11 <	.5000 *	-----	1	----- UG/L
	32106	CHLOROFORM (THM)	2014/11/11 <	.5000 *	-----	1	----- UG/L
	32105	DIBROMOCHLOROMETHANE (THM)	2014/11/11 <	.5000 *	-----	1	----- UG/L
	82080	TOTAL TRIHALOMETHANES	2014/11/11 <	.5000	80	-----	80.000 UG/L
GP	SECONDARY/GP						
	82383	AGGRSSIVE INDEX (CORROSIVITY)	2017/04/18	11.5 *	-----	-----	-----
	00440	BICARBONATE ALKALINITY	2017/04/18	80 *	-----	-----	----- MG/L
	00916	CALCIUM	2017/04/18	302 *	-----	-----	----- MG/L
	00445	CARBONATE ALKALINITY	2017/04/18 <	10 *	-----	-----	----- MG/L
	00940	CHLORIDE	2017/04/18	4	500	-----	250.000 MG/L
	00081	COLOR	2011/08/02	10.0000	15	-----	15.000 UNITS
	01042	COPPER	2017/04/18 <	50	1000	50	1000.000 UG/L
	38260	FOAMING AGENTS (MBAS)	2017/04/18 <	0.05	.5	-----	0.500 MG/L
	00900	HARDNESS (TOTAL) AS CaCO3	2017/04/18	832 *	-----	-----	----- MG/L
	71830	HYDROXIDE ALKALINITY	2017/04/18 <	10 *	-----	-----	----- MG/L
	01045	IRON	2020/01/07	720 *	300	100	300.000 UG/L
	00927	MAGNESIUM	2017/04/18	19 *	-----	-----	----- MG/L
	01055	MANGANESE	2020/01/07	375 *	50	20	50.000 UG/L
	00086	ODOR THRESHOLD @ 60 C	2011/08/02 <	1.0000	3	1	3.000 TON
	00403	PH, LABORATORY	2017/04/18	6.8 *	-----	-----	-----
	01077	SILVER	2017/04/18 <	10	100	10	100.000 UG/L
	00929	SODIUM	2017/04/18	44 *	-----	-----	----- MG/L
	00095	SPECIFIC CONDUCTANCE	2017/04/18	1530 *	1600	-----	900.000 US
	00945	SULFATE	2017/04/18	798 *	500	.5	250.000 MG/L
70300	TOTAL DISSOLVED SOLIDS	2017/04/18	1340 *	1000	-----	500.000 MG/L	
82079	TURBIDITY, LABORATORY	2011/08/02	10.2000 *	5	.1	5.000 NTU	
01092	ZINC	2017/04/18	320	5000	50	5000.000 UG/L	

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 LAST SAMPLE FOR ALL CHAPTER 15 CONSTITUENTS - ALL RESULTS
 REPORT OF SYSTEM: 3205006

SYSTEM NO: 3205006 NAME: GRIZZLY RANCH CSD COUNTY: PLUMAS
 SOURCE NO: 001 NAME: WELL 1P CLASS: CTGP STATUS: A

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
3205006001	IO INORGANIC						
	01105 ALUMINUM	2017/04/18	50	1000	50	200.000	UG/L
	01097 ANTIMONY	2017/04/18 <	6	6	6	6.000	UG/L
	01002 ARSENIC	2020/01/07	18 *	10	2	5.000	UG/L
	01007 BARIUM	2017/04/18 <	100	1000	100	1000.000	UG/L
	01012 BERYLLIUM	2017/04/18 <	1	4	1	4.000	UG/L
	01027 CADMIUM	2017/04/18 <	1	5	1	5.000	UG/L
	01034 CHROMIUM (TOTAL)	2017/04/18 <	10	50	10	50.000	UG/L
	01032 CHROMIUM, HEXAVALENT	2017/04/18 <	1	10	1	10.000	UG/L
	00951 FLUORIDE (F) (NATURAL-SOURCE)	2017/04/18	0.2	2	.1	2.000	MG/L
	01051 LEAD	2017/04/18 <	5	-----	5	15.000	UG/L
	71900 MERCURY	2017/04/18 <	1	2	1	2.000	UG/L
	01067 NICKEL	2017/04/18 <	10	100	10	100.000	UG/L
	A-031 PERCHLORATE	2019/04/09 <	4	6	4	4.000	UG/L
	00660 PHOSPHATE, ORTHO	1999/12/03 <	.0000	-----	-----	-----	MG/L
	01147 SELENIUM	2017/04/18 <	5	50	5	50.000	UG/L
	01059 THALLIUM	2017/04/18 <	1	2	1	2.000	UG/L
NI NITRATE/NITRITE							
00618 NITRATE (AS N)	2019/04/09 <	0.4	10	.4	5.000	mg/L	
71850 NITRATE (AS NO3)	2014/08/12 <	.4000	45	2	23.000	MG/L	
A-029 NITRATE + NITRITE (AS N)	2017/04/18 <	0.2	10	.4	5.000	mg/L	
00620 NITRITE (AS N)	2017/04/18 <	0.4	1	.4	0.500	mg/L	
RA RADIOLOGICAL							
01501 GROSS ALPHA	2011/11/01	.2790	15	3	5.000	PCI/L	
01502 GROSS ALPHA COUNTING ERROR	2011/11/01	2.7300 *	-----	-----	-----	PCI/L	
A-072 GROSS ALPHA MDA95	2011/11/01	4.4900 *	-----	-----	-----	PCI/L	
11501 RADIUM 228	2014/01/07 <	.0000	-----	1	-----	PCI/L	
11502 RADIUM 228 COUNTING ERROR	2014/01/07	.4450 *	-----	-----	-----	PCI/L	
A-075 RADIUM 228 MDA95	2014/01/07	.1980 *	-----	-----	-----	PCI/L	
S1 REGULATED VOC							
34506 1,1,1-TRICHLOROETHANE	2014/11/11 <	.5000	200	.5	0.500	UG/L	

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 LAST SAMPLE FOR ALL CHAPTER 15 CONSTITUENTS - ALL RESULTS
 REPORT OF SYSTEM: 3205006

SYSTEM NO: 3205006 NAME: GRIZZLY RANCH CSD COUNTY: PLUMAS
 SOURCE NO: 001 NAME: WELL 1P CLASS: CTGP STATUS: A

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
3205006001	S1 REGULATED VOC						
	34516 1,1,2,2-TETRACHLOROETHANE	2014/11/11 <	.5000	1	.5	0.500	UG/L
	34511 1,1,2-TRICHLOROETHANE	2014/11/11 <	.5000	5	.5	0.500	UG/L
	34496 1,1-DICHLOROETHANE	2014/11/11 <	.5000	5	.5	0.500	UG/L
	34501 1,1-DICHLOROETHYLENE	2014/11/11 <	.5000	6	.5	0.500	UG/L
	34551 1,2,4-TRICHLOROBENZENE	2014/11/11 <	.5000	5	.5	0.500	UG/L
	34536 1,2-DICHLOROBENZENE	2014/11/11 <	.5000	600	.5	0.500	UG/L
	34531 1,2-DICHLOROETHANE	2014/11/11 <	.5000	.5	.5	0.500	UG/L
	34541 1,2-DICHLOROPROPANE	2014/11/11 <	.5000	5	.5	0.500	UG/L
	34561 1,3-DICHLOROPROPENE (TOTAL)	2014/11/11 <	.5000	.5	.5	0.500	UG/L
	34571 1,4-DICHLOROBENZENE	2014/11/11 <	.5000	5	.5	0.500	UG/L
	34030 BENZENE	2014/11/11 <	.5000	1	.5	0.500	UG/L
	32102 CARBON TETRACHLORIDE	2014/11/11 <	.5000	.5	.5	0.500	UG/L
	77093 CIS-1,2-DICHLOROETHYLENE	2014/11/11 <	.5000	6	.5	0.500	UG/L
	34423 DICHLOROMETHANE	2014/11/11 <	.5000	5	.5	0.500	UG/L
	34371 ETHYL BENZENE	2014/11/11 <	.5000	300	.5	0.500	UG/L
	46491 METHYL-TERT-BUTYL-ETHER (MTBE)	2014/11/11 <	1.0000	13	3	3.000	UG/L
	34301 MONOCHLOROBENZENE	2014/11/11 <	.5000	70	.5	0.500	UG/L
	77128 STYRENE	2014/11/11 <	.5000	100	.5	0.500	UG/L
	34475 TETRACHLOROETHYLENE	2014/11/11 <	.5000	5	.5	0.500	UG/L
	34010 TOLUENE	2014/11/11 <	.5000	150	.5	0.500	UG/L
	34546 TRANS-1,2-DICHLOROETHYLENE	2014/11/11 <	.5000	10	.5	0.500	UG/L
	39180 TRICHLOROETHYLENE	2014/11/11 <	.5000	5	.5	0.500	UG/L
	34488 TRICHLOROFLUOROMETHANE FREON 11	2014/11/11 <	.5000	150	5	5.000	UG/L
	81611 TRICHLOROTRIFLUOROETHANE (FREON 113)	2014/11/11 <	.5000	1200	10	10.000	UG/L
	39175 VINYL CHLORIDE	2014/11/11 <	.5000	.5	.5	0.500	UG/L
	81551 XYLENES (TOTAL)	2014/11/11 <	.5000	1750	0.5	1750.000	UG/L
	S2 REGULATED SOC						
	7744X 1,2,3-TRICHLOROPROPANE (1,2,3-TCP)	2008/10/14 <	.5000 *	-----	0.005	0.005	UG/L
	77443 1,2,3-TRICHLOROPROPANE (1,2,3-TCP)	2018/04/10 <	0.005	0.005	0.005	0.005	UG/L

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 LAST SAMPLE FOR ALL CHAPTER 15 CONSTITUENTS - ALL RESULTS
 REPORT OF SYSTEM: 3205006

SYSTEM NO: NAME: COUNTY:
 SOURCE NO: NAME: CLASS: STATUS:

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
3205006001	S2 REGULATED SOC						
	39045 2,4,5-TP (SILVEX)	1997/10/16 <	.0000	50	1	1.000	UG/L
	39730 2,4-D	1997/10/16 <	.0000	70	10	10.000	UG/L
	77825 ALACHLOR	1997/10/16 <	.0000	2	1	1.000	UG/L
	39033 ATRAZINE	1997/10/16 <	.0000	3	1	1.000	UG/L
	38710 BENTAZON	1997/10/16 <	.0000	18	2	2.000	UG/L
	39350 CHLORDANE	1997/10/16 <	.0000	.1	.1	0.100	UG/L
	38432 DALAPON	1997/10/16 <	.0000	200	10	10.000	UG/L
	38761 DIBROMOCHLOROPROPANE (DBCP)	1997/10/16 <	.0000	.2	.01	0.010	UG/L
	81287 DINOSEB	1997/10/16 <	.0000	7	2	2.000	UG/L
	39390 ENDRIN	1997/10/16 <	.0000	2	.1	0.100	UG/L
	39410 HEPTACHLOR	1997/10/16 <	.0000	.01	.01	0.010	UG/L
	39420 HEPTACHLOR EPOXIDE	1997/10/16 <	.0000	.01	.01	0.010	UG/L
	39700 HEXACHLOROBENZENE	1997/10/16 <	.0000	1	.5	0.500	UG/L
	34386 HEXACHLOROCYCLOPENTADIENE	1997/10/16 <	.0000	50	1	1.000	UG/L
	39340 LINDANE	1997/10/16 <	.0000	.2	.2	0.200	UG/L
	39480 METHOXYCHLOR	1997/10/16 <	.0000	40	10	10.000	UG/L
	82199 MOLINATE	1997/10/16 <	.0000	20	2	2.000	UG/L
	34671 PCB-1016 (AS DECACHLOROBIPHENYL (DCB))	1997/10/16 <	.0000	-----	.5	0.500	UG/L
	39488 PCB-1221 (AS DCB)	1997/10/16 <	.0000	-----	.5	0.500	UG/L
	39492 PCB-1232 (AS DCB)	1997/10/16 <	.0000	-----	.5	0.500	UG/L
	39496 PCB-1242 (AS DCB)	1997/10/16 <	.0000	-----	.5	0.500	UG/L
	39500 PCB-1248 (AS DCB)	1997/10/16 <	.0000	-----	.5	0.500	UG/L
	39504 PCB-1254 (AS DCB)	1997/10/16 <	.0000	-----	.5	0.500	UG/L
	39508 PCB-1260 (AS DCB)	1997/10/16 <	.0000	-----	.5	0.500	UG/L
	39032 PENTACHLOROPHENOL	1997/10/16 <	.0000	1	.2	0.200	UG/L
	39720 PICLORAM	1997/10/16 <	.0000	500	1	1.000	UG/L
	39055 SIMAZINE	1997/10/16 <	.0000	4	1	1.000	UG/L
	A-001 THIOBENCARB	1997/10/16 <	.0000	70	1	1.000	UG/L
	39400 TOXAPHENE	1997/10/16 <	.0000	3	1	1.000	UG/L

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 LAST SAMPLE FOR ALL CHAPTER 15 CONSTITUENTS - ALL RESULTS
 REPORT OF SYSTEM: 3205006

SYSTEM NO: 3205006 NAME: GRIZZLY RANCH CSD COUNTY: PLUMAS
 SOURCE NO: 001 NAME: WELL 1P CLASS: CTGP STATUS: A

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
3205006001	UA STATE UCMR						
	77562	1,1,1,2-TETRACHLOROETHANE	2014/11/11 <	.5000	-----	.5	0.500 UG/L
	01020	BORON	2017/04/18	100	-----	100	1000.000 UG/L
	34668	DICHLORODIFLUOROMETHANE (FREON 12)	2014/11/11 <	.5000	-----	0.5	1000.000 UG/L
	A-033	ETHYL-TERT-BUTYL ETHER	2014/11/11 <	3.0000 *	-----	3	----- UG/L
	A-034	TERT-AMYL-METHYL ETHER (TAME)	2014/11/11 <	3.0000 *	-----	3	----- UG/L
	01087	VANADIUM	2017/04/18 <	3	-----	3	50.000 UG/L
UB	UNREG. TABLE B						
	77222	1,2,4-TRIMETHYLBENZENE	2014/11/11 <	.5000	-----	0.5	330.000 UG/L
	A-011	P-ISOPROPYLTOLUENE	2014/11/11 <	.5000 *	-----	-----	----- UG/L
XX	GENERAL NON CHAP 15						
	77168	1,1-DICHLOROPROPENE	2014/11/11 <	.5000	-----	.5	0.500 UG/L
	77613	1,2,3-TRICHLOROBENZENE	2014/11/11 <	.5000	-----	.5	0.500 UG/L
	77221	1,2,3-TRIMETHYLBENZENE	1997/10/16 <	.0000	-----	-----	----- UG/L
	77226	1,3,5-TRIMETHYLBENZENE	2014/11/11 <	.5000	-----	0.5	330.000 UG/L
	34566	1,3-DICHLOROBENZENE	2014/11/11 <	.5000	-----	.5	600.000 UG/L
	77173	1,3-DICHLOROPROPANE	2014/11/11 <	.5000	-----	.5	0.500 UG/L
	77170	2,2-DICHLOROPROPANE	2014/11/11 <	.5000	-----	.5	0.500 UG/L
	A-008	2-CHLOROTOLUENE	2014/11/11 <	.5000	-----	0.5	0.500 UG/L
	A-009	4-CHLOROTOLUENE	2014/11/11 <	.5000	-----	0.5	0.500 UG/L
	39330	ALDRIN	1997/10/16 <	.0000	-----	.075	0.002 UG/L
	00410	ALKALINITY (TOTAL) AS CaCO3	2017/04/18	70 *	-----	-----	----- MG/L
	82298	BROMIDE	1999/12/03 <	.0000	-----	-----	----- MG/L
	81555	BROMOBENZENE	2014/11/11 <	.5000	-----	.5	0.500 UG/L
	A-012	BROMOCHLOROMETHANE	2014/11/11 <	.5000	-----	.5	0.500 UG/L
	34413	BROMOMETHANE	2014/11/11 <	.5000	-----	.5	0.500 UG/L
	34311	CHLOROETHANE	2014/11/11 <	.5000	-----	.5	0.500 UG/L
34418	CHLOROMETHANE	2014/11/11 <	.5000	-----	.5	0.500 UG/L	
34704	CIS-1,3-DICHLOROPROPENE	2014/11/11 <	.5000	.5	.5	0.500 UG/L	
77596	DIBROMOMETHANE	2014/11/11 <	.5000	-----	.5	0.500 UG/L	

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 LAST SAMPLE FOR ALL CHAPTER 15 CONSTITUENTS - ALL RESULTS
 REPORT OF SYSTEM: 3205006

SYSTEM NO: NAME: COUNTY:
 SOURCE NO: NAME: CLASS: STATUS:

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
3205006001	XX 82052	DICAMBA	1997/10/16 <	.0000	-----	.081	0.081 UG/L
	38447	DICHLORAN	1997/10/16 <	.0000	-----	-----	UG/L
	39380	DIELDRIN	1997/10/16 <	.0000	-----	.02	0.002 UG/L
	A-036	DIISOPROPYL ETHER	2014/11/11 <	3.0000 *	-----	3	UG/L
	34391	HEXACHLOROBUTADIENE	2014/11/11 <	.5000	-----	.5	0.500 UG/L
	77223	ISOPROPYLBENZENE	2014/11/11 <	.5000	-----	0.5	770.000 UG/L
	71814	LANGELIER INDEX AT SOURCE TEMP.	2017/04/18	-0.4	-----	-----	-----
	A-014	M,P-XYLENE	2014/11/11 <	.5000 *	-----	.5	UG/L
	81595	METHYL ETHYL KETONE	1997/10/16 <	.0000	-----	5	UG/L
	81710	M-XYLENE	1997/10/16 <	.0000	1750	.5	1750.000 UG/L
	34696	NAPHTHALENE	2014/11/11 <	.5000	-----	0.5	17.000 UG/L
	A-010	N-BUTYLBENZENE	2014/11/11 <	.5000	-----	0.5	0.500 UG/L
	77224	N-PROPYLBENZENE	2014/11/11 <	.5000	-----	0.5	260.000 UG/L
	77135	O-XYLENE	2014/11/11 <	.5000 *	-----	.5	UG/L
	00937	POTASSIUM	2017/04/18	3 *	-----	-----	----- MG/L
	78132	P-XYLENE	1997/10/16 <	.0000	1750	.5	1750.000 UG/L
	77350	SEC-BUTYLBENZENE	2014/11/11 <	.5000	-----	0.5	0.500 UG/L
	00931	SODIUM ABSORPTION RATIO	2017/04/18	1 *	-----	-----	-----
	77035	TERT-BUTYL ALCOHOL (TBA)	2008/10/14 <	2.0000	-----	2	12.000 UG/L
	77353	TERT-BUTYLBENZENE	2014/11/11 <	.5000	-----	0.5	0.500 UG/L
34699	TRANS-1,3-DICHLOROPROPENE	2014/11/11 <	.5000 *	.5	.5	UG/L	
81284	TRIFLURALIN	1997/10/16 <	.0000	-----	-----	UG/L	